

INVITATION TO BID

Addendum # 1



Department Of Executive Services
Finance and Business Operations Division
Procurement and Contract Services Section
206-684-1681 TTY RELAY: 711

ADDENDUM DATE: April 21, 2004

ITB Title: The Manufacture And Delivery of FRP Ductwork

ITB Number: 04-023 AT

Due Date/Time: May 6, 2004- 2:00 P.M.

Buyer: Alan R. Terhune, alan.terhune@metrokc.gov, (206) 684-1067

This addendum is issued to Prospective Bidders.

Notice is hereby given that the solicitation document cited above has been amended or revised. The revised or changed sections are more fully explained below.

NOTE: Reference No. Identifies the change

Location identifies the material in ITB 04-023 AT changed by this Addendum.

REFERENCE NO.	LOCATION	DESCRIPTION OF CHANGE
1.1	Due Date, Page 1	ITB Due Date has been revised from April 29 to May 6, 2004
1.2	Section 13234, 2.03, B; Table, Column "Item," Bottom Row	Delete the word "Concentric" and replace with "Eccentric."
1.3	Section 13234, 2.03, D 2	Delete the word "Concentric" and replace with "Eccentric."
1.4	Section 13234, 2.03, D 3	Add the word "remaining" before "eccentric reducers"
1.5	Section 13234, 2.04, 4, a	Clarification: "Plain-end by flat-face-flanged end" with "C" of 9" (inches). Standard stub length with flange butt joined to elbow is acceptable, as long as the plain end does not have a stub length butt joined to it.
1.6	Section 13234, 2.03, D, Reducer Dimensions, Eccentric Reducer Table	Within the Eccentric Reducer Table, in the left hand column on the bottom line add "12" Replace the right hand column title of "Inches of Reduction" with "Minimum Length: A" On the 2 nd line up from the bottom of the table, in the right hand column replace "6" with "15" On the bottom line in the right hand column, add "30"
1.7	Section 13234, 2.03, D, Reducer Dimensions, Concentric Reducer Table	Delete the Concentric Reducer Table
1.8	Section 13234, 2.04, 4, C	Clarification: 6" elbow flange thickness shall be at least 11/16-inch." In comparison, the 18-inch duct flange thickness is 0.63-inch. Both dimensions are correct as listed.

The remainder of this ITB document is unchanged. Please acknowledge this addendum in the space provided in **EXHIBIT A-BID PRICING**.

This Addendum #1 shall be attached to and made part of ITB 04-023 AT.

Note: This Addendum and ITB 04-023 AT are available on the Internet at [HTTP://WWW.METROKC.GOV/FINANCE/PROCUREMENT](http://www.metrokc.gov/finance/procurement). Potential bidders must contact the buyer at ALAN.TERHUNE@METROKC.GOV to ensure they receive any subsequent addenda revising or clarifying ITB 04-023 AT.

Issued by: 
ALAN R. TERHUNE, BUYER, CPPB

THIS INVITATION TO BID WILL BE PROVIDED IN ALTERNATIVE FORMATS SUCH AS BRAILLE, LARGE PRINT, AUDIOCASSETTE OR COMPUTER DISK FOR INDIVIDUALS WITH DISABILITIES UPON REQUEST.